

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-0026:229 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Simplex, \*100 Simplex Drive, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-8542

**DESIGN:** Model 4098-9603 ionization type smoke detector. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

**RATING:** 8.5 – 35 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as ionization smoke detector for use with separately listed compatible fire alarm control units. Unit is intended for use with listee's listed base (CSFM Listing No. 7300-0026:222).

**XLf:** 7271-1062:115

\*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager